

C.No. 792/FSD/FPW/NOC/2023/ 552
GOVERNMENT OF PUDUCHERRY
FIRE SERVICE DEPARTMENT

EoDB Application No.: 161519


Puducherry, dt. 17-11-2023

CERTIFICATE

This is to certify that the 1 No. of four storeyed building and 1 No. of three storeyed building of M/s. **Immaculate Heart of Mary Girls' Higher Secondary School** at 275, Mission Street, Puducherry has been inspected and examined by the officials of this Department on Fire Safety point of view. Hence, it is **Recommended** for the purpose of applying for renewal of recognition of the school for the academic year 2023-2024 subject to the following conditions:

1. To obtain occupancy certificate for the building from the PPA at the earliest.
2. To comply fully with the National Building Code of India, 2016 (Part 4 – Fire and Life Safety) and Standards for the present occupancy of the building at the earliest.
3. The Fixed Fire Fighting Installations provided in the building are to be under proper Care & Maintenance as per the Codes & Standards and recorded in registers by employing (24X7) well trained Fire Fighting Crew/Guards.
4. Emergency / Quick Response Team (ERT/QRT) with the above crew along with other Staffs shall be constituted for responding immediately during emergencies for safe & speedy evacuation of the occupants and loss mitigation.
5. The occupant and fire load of the building shall be maintained properly.
6. The Electrical equipment/appliances are to be maintained as per Codes and Standards for the building.
7. To have a total Evacuation Plan / SOP for fire and other emergencies, scheduled Annual Time Table / Calendar for Fire Safety Training to the staffs, Table Top Exercise, Mock drill and conduct the same under the supervision of the Fire Service Department.
8. The approved class of occupancy of the building shall not be altered.
9. The Setbacks on all sides, Corridors, Passages, Staircases, Entries and Exits shall always be free of any obstruction for easy movement during any emergency.
10. Any structural addition/alteration in the building shall be made with the prior approval of the Competent Authority and Fire Service Department.

Note: This Certificate shall be revoked / cancelled at any time based on the non-compliance / non adherence of the stipulated conditions as stated above (or) non-compliance to any of the Statutory Norms in connection with Fire & Life Safety.




(K. ILANGO)

DIVISIONAL FIRE OFFICER
PUDUCHERRY

To

M/s. Immaculate Heart of Mary Girls' Higher Secondary School,
275, Mission Street, Puducherry.




PRINCIPAL
IMMACULATE HEART OF MARY
GIRLS' HR. SEC. SCHOOL
275, Mission Street, Puducherry - 1

C.No. 630/FSD/FPW/NOC/2025/640
GOVERNMENT OF PUDUCHERRY
FIRE SERVICE DEPARTMENT

EoDB Application No. : 204644

Puducherry,dt. 24-09-2025

NO OBJECTION CERTIFICATE

This is to certify that the four storeyed building of M/s. **Immaculate Heart of Mary Nursery School** at No.13, St. Therese Street, Puducherry has been inspected and examined by the officials of this Department on Fire Safety point of view. Hence, there is '**No Objection**' for the purpose of applying for renewal of recognition of the school for the academic year 2025-2026.




(K. ILANGO)
DIVISIONAL FIRE OFFICER
PUDUCHERRY

To

M/s. Immaculate Heart of Mary Nursery School,
No.13, St. Therese Street, Puducherry.

